

SECTION 11

11.19 SEPARATION FROM POTABLE WATER LINES:

Nonpotable water lines shall cross a minimum of one foot below potable water lines. Nonpotable transmission lines parallel to potable water lines shall be installed at a minimum distance of 10 horizontal feet and one vertical foot below the potable water line. Any deviation from these requirements will need to be approved by Denver Water. Common trench construction is prohibited.